

Executive Director
Thomas W. Sigmund, P.E.
Commissioners
Kathryn Hasselblad, President
James Blumreich, Secretary
Thomas P. Meinz, Vice President
Mark D. Tumpach, Vice President
Lee D. Hoffmann, Vice President



June 23, 2020

Ms. Tania Taff
Department of Natural Resources
2984 Shawano Avenue
Green Bay, WI 54313-6727

RE: Stack Test Results for Fluid Bed Incinerator- Particulate Matter
FID 405004600

Dear Ms. Taff:

Enclosed are results of an emission test conducted on the fluid bed incinerator (FBI) operated at the Green Bay Metropolitan Sewerage District (GBMSD) wastewater treatment plant located in Green Bay, Wisconsin. GBMSD contracted with Environmental Technology & Engineering Inc. to conduct a stack test to demonstrate whether its facility is in compliance with the applicable emission limit for particulate matter (PM) on May 27, 2020. GBMSD is required by the facility Title V Operation Permit, Permit No. 405004600-P30, to conduct a stack test demonstrating compliance with all applicable emission limits within 13 months of the previous compliance test, which was conducted on May 1 and 2, 2019 (the Stack Test Compliance Confirmation).

The results of this recent stack test show emissions of 4.07 milligrams per dry standard cubic meter at 7 percent oxygen, which is in compliance with the limit of 9.6 mg/dscm at 7 percent oxygen. During this testing, the operational parameters of the pollution control equipment operated with the FBI were measured and recorded. These operational parameters will be used to establish allowable operating parameters to follow until the next compliance emission test.

On March 18 and 19, 2020, GBMSD performed compliance emissions testing for the FBI (the March Stack Test). The results showed compliance with all pollutants except for PM. The PM result was unexpected for several reasons and GBMSD does not consider the PM result from the March 2020 testing to be representative of emissions from the FBI. GBMSD has taken several steps to understand the PM result from the March 2020 testing, as described in the May 18, 2020 transmittal to the Department of Natural Resources.


The PM test results included herein, along with the results of the March Stack Test previously submitted, are submitted in accordance with the Stack Test Compliance Confirmation requirement of the permit. We understand the next Stack Test Compliance Confirmation is due by June 27, 2021 which is 13 months after the May 27 stack testing date.

Please feel free to contact me with any questions or concerns you may have about GBMSD's emissions testing.



Sincerely,

**GREEN BAY METROPOLITAN
SEWERAGE DISTRICT**

A handwritten signature in black ink that reads "Julie C. Maas". The signature is written in a cursive style with a large, looped initial "J".

Julie Maas
Environmental Compliance Specialist

Appendices

- 1) TESTING TO DEMONSTRATE COMPLIANCE WITH FILTERABLE PARTICULATE AIR EMISSIONS LIMITS on the FLUID BED INCINERATOR EXHAUST (I08, S08, C08) May 27, 2020

cc: Ms. Louise Gross, US EPA
Mr. Dan Schaufelberger, US EPA
Mr. James Bonar Bridges, Wisconsin DNR
Mr. Michael Huenink, ETE

Report to
GREEN BAY METROPOLITAN SEWERAGE DISTRICT
(FID 405004600)
Green Bay, Wisconsin

for

**TESTING TO DEMONSTRATE COMPLIANCE WITH
FILTERABLE PARTICULATE AIR EMISSIONS LIMITS**

on the

FLUID BED INCINERATOR EXHAUST (I08, S08, C08)

May 27, 2020

ETE

Report to
GREEN BAY METROPOLITAN SEWERAGE DISTRICT
(FID 405004600)
Green Bay, Wisconsin

for

**TESTING TO DEMONSTRATE COMPLIANCE WITH
FILTERABLE PARTICULATE AIR EMISSIONS LIMITS**

on the

FLUID BED INCINERATOR EXHAUST (I08, S08, C08)

May 27, 2020



Michael J. Huenink
Industrial Hygienist
June 2, 2020

ENVIRONMENTAL TECHNOLOGY & ENGINEERING CORP
13000 W. Bluemound Road Elm Grove, Wisconsin 53122
Phone: (262) 784-2434 Fax: (262) 784 -2436

EXECUTIVE SUMMARY

On May 27, 2020, Environmental Technology & Engineering Corp (ETE) personnel visited the Green Bay Metropolitan Sewerage District (GBMSD) wastewater treatment facility located in Green Bay, Wisconsin. The purpose of the visit was to perform particulate matter (PM) air emissions testing on the exhaust stack for the Fluid Bed Incinerator (I08, S08, C08) operations and its emissions control system. The operations are required to meet the EPA Standards of Performance for New Stationary Sources: Sewage Sludge Incineration Units [40 CFR 60, Subpart LLLL] and the EPA Standards of Performance for Sewage Treatment Plants [40 CFR 60 Subpart O]. The emission limits are included in Wisconsin Department of Natural Resources (WDNR) Air Pollution Control Construction Permit No. 14-JJW-051-R1.

The results of the test efforts indicated that the particulate emissions levels were below (in compliance with) both the EPA's Sewage Sludge Incineration emission limit and the WDNR permit limit. The test results can be summarized as follows:

Test Parameter	Test	Average Measured PM Emission Concentration (1)	PM Emissions Relative to Process Throughput
Particulate Matter	1	4.03 mg/dscm @ 7% O ₂	0.0528 lb PM/ton dry sludge input
	2	4.50 mg/dscm @ 7% O ₂	0.0567 lb PM/ton dry sludge input
	3	3.69 mg/dscm @ 7% O ₂	0.0452 lb PM/ton dry sludge input
	AVG	4.07 mg/dscm @ 7% O₂	0.0516 lb PM/ton dry sludge input
PM Emissions Limits -		9.6 mg/dscm @ 7% O₂	1.30 lb PM/ton dry sludge input

Notes: (1) These test results are expressed in units corrected to 7% oxygen per EPA Standard **mg/dscm @ 7% O₂** means milligrams per dry standard cubic meter, corrected to 7% O₂
lb PM/ton dry sludge input means pounds of PM emissions per ton of dry sludge input

1.0 GENERAL

On May 27, 2020, Environmental Technology & Engineering Corp (ETE) personnel visited the Green Bay Metropolitan Sewerage District (GBMSD) wastewater treatment facility located in Green Bay, Wisconsin. The purpose of the visit was to perform particulate matter (PM) air emissions testing on the exhaust stack for the Fluid Bed Incinerator (I08, S08, C08) operations and its emissions control system. The operations are required to meet the EPA Standards of Performance for New Stationary Sources: Sewage Sludge Incineration Units [40 CFR 60, Subpart LLLL] and the EPA Standards of Performance for Sewage Treatment Plants [40 CFR 60 Subpart O]. The emission limits are included in Wisconsin Department of Natural Resources (WDNR) Air Pollution Control Construction Permit No. 14-JJW-051-R1.

GBMSD owns and operates a 49 MGD activated sludge wastewater treatment plant. A fluid bed incinerator (I08) processes sewage sludge that has been anaerobically digested, conditioned with polymer, dewatered with centrifuges, and dried in an industrial dryer. Emissions from I08 are controlled by a wet scrubber, wet ESP, and carbon bed (C08A, B, C). Following the emissions controls, exhaust gas is vented to atmosphere through stack S08. Testing was performed on S08 following all emissions control devices. During the testing, GBMSD staff monitored and recorded operational parameters on each of the emission control devices.

The testing was performed under normal process conditions; every attempt was made to run the incinerator operations at 85 percent (or greater) of capacity. GBMSD personnel monitored the fluid bed incinerator operating conditions throughout the test efforts. The documentation of those sludge processing rates is included in Appendix A of this report. The processing levels can be summarized as follows:

Test	Test Period	Wet Material Processing Rate	Rate of Dry tons of Sludge Produced per Hour
1	08:50 - 09:52	10241 lbs/hr	1.961 tons/hr
2	10:06 - 11:08	10262 lbs/hr	2.027 tons/hr
3	11:20 - 12:22	9998 lbs/hr	1.985 tons/hr

Ms. Julie Maas and Mr. Bruce Bartel of GBMSD facilitated in the coordination of the production activities and field test efforts. Ms. Tania Taff of the WDNR - WCR/NOR Air Management (Green Bay), Mr. Quin Kovar of the WDNR - WCR/NOR Air Management (Wausau), and Mr. Andy Seeber of the WDNR - Bureau of Air Management were notified of the test efforts. The field test and analytical efforts (unless noted) were performed by ETE personnel; Michael Huenink was the test team leader.

2.0 RESULTS

Testing to determine particulate matter (PM) emissions on the stack was performed isokinetically using EPA Method 5. This test method measured filterable PM emissions; the testing and analysis did not include condensable PM fraction (EPA Method 202 analysis). A brief description of the method is included in Section 3.0 of this report. A sketch showing the sampling ports and point locations on the final discharge stack is included as Figure 2-1.

Three separate 60 minute tests were performed on the stack; the sample volumes were all greater than the minimum required (per the EPA's SSI Standard) volume of 1 dry standard cubic meter of exhaust (35.31 cubic feet). The stack flow parameters measured during testing and the weights of the particulate collected were used to determine the emissions for each test. The detailed total particulate emission results are included as Tables 2-1 through 2-3.

The EPA emission guidelines are all expressed in units of concentration (e.g., parts per million), corrected to 7 percent oxygen levels. The basic equation to "correct" the results would be as follows:

$$\text{Corrected Conc.} = \text{Measured Conc.} \times \frac{(20.9 - 7)}{(20.9 - \% \text{ O}_2)}$$

The results of the test efforts indicated that the particulate emissions levels were below (in compliance with) both the EPA's Sewage Sludge Incineration emission limit and the WDNR permit limit. The test results can be summarized as follows:

Test Parameter	Test	Average Measured PM Emission Concentration (1)	PM Emissions Relative to Process Throughput
Particulate Matter	1	4.03 mg/dscm @ 7% O ₂	0.0528 lb PM/ton dry sludge input
	2	4.50 mg/dscm @ 7% O ₂	0.0567 lb PM/ton dry sludge input
	3	3.69 mg/dscm @ 7% O ₂	0.0452 lb PM/ton dry sludge input
	AVG	4.07 mg/dscm @ 7% O₂	0.0516 lb PM/ton dry sludge input
PM Emissions Limits -		9.6 mg/dscm @ 7% O₂	1.30 lb PM/ton dry sludge input

Notes: (1) These test results are expressed in units corrected to 7% oxygen per EPA Standard **mg/dscm @ 7% O₂** means milligrams per dry standard cubic meter, corrected to 7% O₂
lb PM/ton dry sludge input means pounds of PM emissions per ton of dry sludge input


**INCINERATOR I08 - TEST LOCATION & POINTS
GBMSD - GREEN BAY, WI**

FIGURE 2-1

VELOCITY POINT LOCATIONS

Point	Distance (in.) from back wall
1	1.1
2	3.5
3	7.1
4	16.9
5	20.5
6	22.9

SAMPLE PORT LOCATION



Stack Diameter: 24 in. (stack runs vertically at the test location)

Notes: 12 PM sampling points used on this round stack;
6 points along each of two perpendicular traverses.
All other gas sampling performed at a single point in the center third of the duct.

GBMSD - NEW WATER

I08 STACK

5/27/20

TABLE 2-1

TEST NO.	1	
BAROMETRIC PRESSURE	29.28	IN HG
TIP DIAMETER	0.250	IN
STACK DIAMETER	24	IN
STACK AREA	3.142	FT3
SAMPLING TIME PER POINT	5	MIN
NUMBER OF POINTS	12	
METER VOLUME	55.83	FT3
PITOT COEFFICIENT	0.84	
METER COEFFICIENT	0.997	
PARTICULATE COLLECTED	0.0050	GRAMS
WATER COLLECTED	29	ML
STATIC PRESSURE	-0.54	IN H2O

ORSAT RESULTS

CO2	O2	CO	N2
8.30%	9.80%	0.00%	81.90%

POINT	STACK TEMP DEG F	DELTA P IN H2O	ORIFICE DEL P IN H2O	METER TEMP DEG F	VELOCITY AFPS
1	123	0.81	1.70	81	53.19
2	124	0.85	1.79	82	54.54
3	124	0.82	1.72	84	53.56
4	122	0.75	1.58	88	51.14
5	121	0.92	1.93	91	56.59
6	121	0.87	1.83	95	55.03
7	121	0.60	1.26	99	45.70
8	121	0.76	1.60	103	51.44
9	122	0.84	1.76	108	54.12
10	121	0.93	1.95	111	56.90
11	121	0.97	2.04	114	58.11
12	120	0.87	1.83	118	54.98
AVERAGE	122		1.75	98	53.78

DRY STANDARD VOLUME	54.89	SCF
PERCENT WATER VAPOR	2.43	% VOL
FLOW RATE	10136	ACFM
	8773	DSCFM
	14907	M3/HR
PARTICULATE CONCENTRATION	0.0014	GR/DSCF
PARTICULATE EMISSION RATE	0.104	LB/HR
LB PART PER 1000 LB GAS	0.0025	
ISOKINETIC PERCENT	96.1	

3.22	mg/dscm
4.03	mg/dscm @ 7% O2

DRY SLUDGE FEED RATE	1.961	TONS/HR
PM EMISSION FACTOR	0.0528	LB FILT PM/TON DRY SLUDGE INPUT

GBMSD - NEW WATER

I08 STACK

5/27/20

TABLE 2-2

TEST NO.	2	
BAROMETRIC PRESSURE	29.27	IN HG
TIP DIAMETER	0.250	IN
STACK DIAMETER	24	IN
STACK AREA	3.142	FT ²
SAMPLING TIME PER POINT	5	MIN
NUMBER OF POINTS	12	
METER VOLUME	54.75	FT ³
PITOT COEFFICIENT	0.84	
METER COEFFICIENT	0.997	
PARTICULATE COLLECTED	0.0055	GRAMS
WATER COLLECTED	32	ML
STATIC PRESSURE	-0.49	IN H ₂ O

CO₂	O₂	CO	N₂
8.20%	9.80%	0.00%	82.00%

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	122	0.89	1.87	118	55.76
2	122	0.86	1.81	119	54.81
3	122	0.79	1.66	120	52.54
4	123	0.70	1.47	121	49.49
5	122	0.78	1.64	122	52.20
6	122	0.98	2.06	124	58.51
7	122	0.77	1.62	127	51.87
8	123	0.80	1.68	128	52.91
9	123	0.82	1.72	129	53.57
10	122	0.97	2.04	130	58.21
11	123	0.91	1.91	131	56.43
12	123	0.73	1.53	133	50.54
AVERAGE	122		1.75	125	53.91

DRY STANDARD VOLUME	53.99	SCF	
PERCENT WATER VAPOR	2.71	% VOL	
FLOW RATE	10161	ACFM	
	8756	DSCFM	
	14878	M ³ /HR	
PARTICULATE CONCENTRATION	0.00157	GR/DSCF	3.60 mg/dscm
PARTICULATE EMISSION RATE	0.115	LB/HR	4.50 mg/dscm @ 7% O ₂
LB PART PER 1000 LB GAS	0.0028		
ISOKINETIC PERCENT	94.7		
DRY SLUDGE FEED RATE	2.027	TONS	
PM EMISSION FACTOR	0.0567	LB FILT PM/TON DRY SLUDGE INPUT	

GBMSD - NEW WATER

I08 STACK

5/27/20

TABLE 2-3

TEST NO.	3	
BAROMETRIC PRESSURE	29.26	IN HG
TIP DIAMETER	0.250	IN
STACK DIAMETER	24	IN
STACK AREA	3.142	FT ²
SAMPLING TIME PER POINT	5	MIN
NUMBER OF POINTS	12	
METER VOLUME	54.64	FT ³
PITOT COEFFICIENT	0.84	
METER COEFFICIENT	0.997	
PARTICULATE COLLECTED	0.0043	GRAMS
WATER COLLECTED	35	ML
STATIC PRESSURE	-0.54	IN H ₂ O

ORSAT RESULTS

CO₂	O₂	CO	N₂
7.90%	10.30%	0.00%	81.80%

POINT	STACK TEMP DEG F	DELTA P IN H ₂ O	ORIFICE DEL P IN H ₂ O	METER TEMP DEG F	VELOCITY AFPS
1	123	0.83	1.74	130	53.96
2	123	0.77	1.62	129	51.97
3	122	0.72	1.51	130	50.21
4	122	0.86	1.81	131	54.88
5	122	0.99	2.08	132	58.88
6	122	0.92	1.93	132	56.76
7	122	0.65	1.37	133	47.71
8	122	0.74	1.55	134	50.91
9	122	0.84	1.76	136	54.24
10	123	0.93	1.95	137	57.12
11	122	0.97	2.04	138	58.28
12	123	0.79	1.66	139	52.64
AVERAGE	122		1.75	133	53.96

DRY STANDARD VOLUME	53.92	SCF
PERCENT WATER VAPOR	2.96	% VOL
FLOW RATE	10172	ACFM
	8740	DSCFM
	14851	M ³ /HR

PARTICULATE CONCENTRATION	0.00123	GR/DSCF	2.82	mg/dscm
PARTICULATE EMISSION RATE	0.090	LB/HR	3.69	mg/dscm @ 7% O ₂
LB PART PER 1000 LB GAS	0.0022			
ISOKINETIC PERCENT	94.8			

DRY SLUDGE FEED RATE	1.985	TONS
PM EMISSION FACTOR	0.0452	LB FILT PM/TON DRY SLUDGE INPUT

3.0 TEST METHODS

The equipment used to sample for particulate matter was the Western Precipitation Division of the Joy Manufacturing Company Emission Parameter Analyzer. Samples were collected and analyzed in accordance with procedures outlined in EPA Method 5 - "Determination of Particulate Emissions from Stationary Sources" as found in 40 CFR Part 60, Appendix A.

The "front half" of the sampling train consisted of a stainless steel probe tip, a heated stainless steel lined probe, and a heated glass fiber filter (or "filterable particulate" filter). Following the front half, the "back half" of the sampling train consisted of a set of several Greenburg-Smith impingers. A schematic drawing of the sampling train is included. The first and second impingers each contained 100 milliliters of de-ionized water, the third impinger was left dry (for any moisture spillover), and the fourth impinger contained a tared amount of silica gel. The gas then passed through a vacuum pump, calibrated dry gas meter, and a calibrated orifice. The temperatures of the stack gas stream, as well as strategic locations within the sampling devices, were monitored by RTDs and read directly from a gauge on the control unit.


The initial gas stream velocity was obtained from a preliminary traverse using an "S" type pitot tube. The initial moisture was estimated from previous tests of similar processes. This data, along with the stack temperature, was used to set a nomograph so that rapid calculations of isokinetic sampling conditions could be made.

The principle of the method was to collect the sample representative of the exhaust by adjusting the sample collection velocity to match the exhaust gas stream velocity at the point of collection. The velocity at the point of collection was measured with an "S" type pitot tube attached to the probe and the collection velocity was matched to the stack gas velocity by adjusting the flow as indicated by the calibrated orifice.

To determine the molecular weight of the stack gas, samples were drawn into an Orsat analyzer and analyzed for percentage CO₂, O₂, CO, and N₂.

At the completion of the test, the probe and tip preceding the filter was washed (rinsed, brushed, and rinsed three times) with acetone. This rinse was later placed in a tared beaker along with a rinse of the filter-holding glassware and evaporated to dryness at room temperature. The filter and beakers were then desiccated to the tared humidity conditions and weighed. These combined weights constituted the filterable (or "front-half") particulate catch.

The impinger contents were measured and weighed for determination of the actual moisture content of the exhaust gas stream. Blanks of the sample solutions were also analyzed in similar fashion to the field samples. All test results were blank subtracted as appropriate.



Method 5

Particulate sampling train.

4.0 CALIBRATION DATA

The probe tip, pitot tube, dry gas meter, and sample box orifice used in the isokinetic test efforts were calibrated prior to the testing in accordance with the procedures outlined in the Maintenance, Calibration, and Operation of Isokinetic Source-Sampling Equipment as published by the US EPA. The values obtained were:

Stack - Test Parameter	Date	Control Box ID	Orifice Coeff. ($\Delta H@$)	Dry Gas Meter Coeff. (γ)	Probe Tip Diameter
S08 - Particulate	5/27	3	0.999	0.997	0.500 in.

The flow measurements were made with an S-type pitot tube attached to the sampling probe. For the sampling probe used, the "S-type" Pitot tube coefficient (C_p) was 0.84. Prior to beginning the testing, the null angles were measured to verify the absence of cyclonic flow. All of the null angles were 15 degrees or less and averaged less than 5 degrees; this validated the flow measurements and sampling location since these figures were less than the acceptable 20 percent criteria.

The dry gas meter installed in the control box was a temperature compensating meter. The correction factor (γ) for the meter could best be described by the following equation:

$$\text{Box 3 - } \gamma = 0.997 + [(T_M - 70) \times 0.00012]$$

The most recent calibrations on the particulate sampling equipment with regard to these test efforts were performed on April 22, 2020.

The isokinetic ratios for the test runs ranged from 94.7 to 96.1 percent, within the acceptable range of 90 to 110 percent.

APPENDIX A

Production Related Data

GBMSD Stack Testing Results
Green Bay Facility - Fluid Bed Incinerator
FBI Feed
5/27/2020

DATE	Run	LAB NO.	SAMPLE	%TS	%VS	Wet gal/hr	Wet lbs/hr	Dry lbs/hr	Dry ton/hr
5/27/2020	Run #1	200701-01	TEST 1	38.3	69.3	1010	10241.4	3922	1.961
5/27/2020	Run #2	200701-02	TEST 2	39.5	69.2	1012	10261.7	4053	2.027
5/27/2020	Run #3	200701-03	TEST 3	39.7	69.1	986	9998.04	3969	1.985

APPENDIX B

Field and Lab Data Sheets


PARTICULATE FIELD DATA

METER ΔH. 8 = 997
 999 } 9/22
 C FACTOR CP = .87

AMBIENT TEMPERATURE 75
 BAROMETRIC PRESSURE 29.28
 ASSUMED MOISTURE, % 1 1/2%
 PROBE LENGTH, in. 354
 NOZZLE DIAMETER, in. 1/4"
 STACK DIAMETER, in. 24
 PROBE HEATER SETTING 250
 HEATER BOX SETTING 250

PROCESS WEIGHT RATE _____

ORSAT RESULTS LEAK CHECKS
 CO2 8.3% Pre < 0.1020
 O2 9.8% Pitot 0.0021
 CO 0 Post < 0.1020
 N2 8.1% Pitot 0.0021



CROSS SECTION

PLANT GRAND
 DATE 5/27/20
 LOCATION GREEN BAY, WI
 OPERATOR MJM/CSH
 STACK NO. JOB FINAL
 RUN NO. 1
 SAMPLE BOX NO. 1
 METER BOX NO. 3

FAT 287 5 min/pt

TRAVERSE POINT NUMBER	SAMPLING TIME (A), min.	STATIC PRESSURE (in. H ₂ O)	STACK TEMPERATURE (T _s), °F	CALORIC NOZZLES	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (ΔH) in. H ₂ O	GAS SAMPLE VOLUME (V _m), lit	GAS SAMPLE TEMPERATURE AT DRY GAS METER		SAMPLE BOX TEMPERATURE °F	TEMPERATURE OF GAS LEAVING CONDENSER OR LAST IMPINGER °F	PUMP VACUUM in. Hg gauge	CPM FILTER TEMP
							INLET (T _m), °F	OUTLET (T _m), °F				
1	8:50		123	.81	1.70	4622.00	81	240	<50	2	77	
2	55	-.60	124	.85	1.79	26.7	82				78	
3	9:00		124	.82	1.72	31.4	84	255	<50	2	78	
4	5:05		122	.75	1.58	36.1	88				79	
5	1:10	-.61	121	.92	1.93	40.6	91	250	<50	2+	79	
6	1:15		121	.87	1.83	45.5	95				80	
8	20/22		121	.60	1.26	50.2	99	250	<50	<2	80	
2	27	-.45	121	.76	1.60	54.3	103				79	
3	32		122	.84	1.76	58.7	108	255	<50	2	80	
4	37		121	.93	1.95	63.4	111				80	
5	42	-.49	121	.97	2.04	68.2	114	245	<50	2+	81	
6	47		120	.87	1.83	73.2	118				82	
	9:52					4677.83						
						(55.83)						

LABORATORY DATA SHEET
PARTICULATE & WATER COLLECTED

JOB NAME GBMSD

DATE OF TEST 5-27-2020

JOB NO. _____

TEST ENGINEER MJH

RUN NO. 1 STACK. 508

Sample Box 1 Filter 288

Wash Bottle -

Beaker No. 1

WATER COLLECTED

<u>Impinger No.</u>	<u>Final Wt. g</u>	<u>Initial Wt. g</u>	<u>Collected grams</u>
<u>1</u>	<u>112</u>	<u>100</u>	<u>12</u>
<u>2</u>	<u>104</u>	<u>100</u>	<u>4</u>
<u>3</u>	<u>2</u>	<u>0</u>	<u>2</u>
<u>SIL GEL</u>	<u>665</u>	<u>654</u>	<u>11</u>
		TOTAL	<u><u>29</u></u>

PARTICULATE COLLECTED

	<u>Final Wt. g</u>	<u>Tare Wt. g</u>	<u>Collected grams</u>
Filter <u>.0002</u>	<u>.3496</u>	<u>.3489</u>	<u>.0005</u>
Washings <u>-.0001</u>	<u>102.1699</u>	<u>102.1655</u>	<u>.0045</u>
		TOTAL	<u><u>.0050</u></u>

WATER COLLECTED GRAMS

PARTICULATE COLLECTED GRAMS

NOTES:


PARTICULATE FIELD DATA

METER NO. 8:997 } 4/22
 AMBIENT TEMPERATURE 78
 BAROMETRIC PRESSURE 29.27
 ASSUMED MOISTURE, % 1 1/2%
 PROBE LENGTH, in. 3 FT
 NOZZLE DIAMETER, in. 1/4"
 STACK DIAMETER, in. 24
 PROBE HEATER SETTING 250
 HEATER BOX SETTING 250
 METER BOX SETTING 3
 SAMPLE BOX NO. 2
 METER BOX NO. 3

PLANT GBMSD
 DATE 5/27/20
 LOCATION GREEN BAY, WI
 OPERATOR NJM/CSM
 STACK NO. 208
 RUN NO. 2
 SAMPLE BOX NO. 2
 METER BOX NO. 3

METER ΔH. 999
 C FACTOR 0.84
 PROCESS WEIGHT RATE _____
 ORSAT RESULTS
 CO2 8.2%
 O2 9.8
 CO 0
 N2 BALANCE
 LEAK CHECKS
 Pre Pitot <0.1020"
 Post Pitot 0.1020"

Filt 288 5 min/pt



CROSS SECTION

TRAVERSE POINT NUMBER	SAMPLING TIME (H), min.	STATIC PRESSURE (in. H ₂ O)	STACK TEMPERATURE (T _s), °F	VELOCITY HEAD (V _p) (√TP _s)	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (in. H ₂ O)		GAS SAMPLE VOLUME (V _m), ft ³	GAS SAMPLE TEMPERATURE AT DRY GAS METER		SAMPLE BOX TEMPERATURE °F	TEMPERATURE OF GAS LEAVING CONDENSER OR LAST IMPINGER °F	PUMP VACUUM in. Hg gauge	CPM FILTER TEMP. VELOCITY TRS
					ACTUAL	DESIRED		INLET (T _{m,IN}), °F	OUTLET (T _{m,OUT}), °F				
1	10:06		122	.89	1.87		4679.00	118	230	230	<50	2	78
2	11	-46	122	.86	1.81		83.7	119					78
3	11:16		122	.79	1.66		88.5	120	250	250	<50	2	79
4	12		123	.70	1.47		93.9	121					79
5	12:26	-44	122	.78	1.64		97.1	122	260	260	<50	2	79
6	13		122	.98	2.06		4701.6	124					80
8	36/58		122	.77	1.62		706.4	121	255	255	<50	2	80
2	1:43	-51	123	.80	1.68		10.9	121					80
3	1:48		123	.82	1.72		15.4	129	255	255	<50	2	81
4	1:53		122	.97	2.04		19.8	130					81
5	1:58	-54	123	.91	1.91		24.7	131	250	250	<50	2+	83
6	11:03		123	.73	1.53		29.4	133					84
	11:08						4733.75						
							(54.75)						

LABORATORY DATA SHEET
PARTICULATE & WATER COLLECTED

JOB NAME GBMSD

DATE OF TEST 5-27-2020

JOB NO. _____

TEST ENGINEER MJH

RUN NO. 2 STACK. 508

Sample Box 2 Filter 289 Wash Bottle —

Beaker No. 2

WATER COLLECTED

<u>Impinger No.</u>	<u>Final Wt. g</u>	<u>Initial Wt. g</u>	<u>Collected grams</u>
<u>1.</u>	<u>111</u>	<u>100</u>	<u>11</u>
<u>2</u>	<u>109</u>	<u>100</u>	<u>9</u>
<u>3</u>	<u>4</u>	<u>0</u>	<u>4</u>
<u>SIL GEL</u>	<u>678</u>	<u>670</u>	<u>8</u>
		TOTAL	<u><u>32</u></u>

PARTICULATE COLLECTED

	<u>Final Wt. g</u>	<u>Tare Wt. g</u>	<u>Collected grams</u>
Filter .0002	<u>3499</u>	<u>.3492</u>	<u>.0005</u>
Washings -.0001	<u>102.5429</u>	<u>102.5380</u>	<u>.0050</u>
		TOTAL	<u><u>.0055</u></u>

WATER COLLECTED GRAMS

PARTICULATE COLLECTED GRAMS


NOTES:

PARTICULATE FIELD DATA

METER ΔH: 8=999 }
 METER ΔH: 999 }
 C FACTOR: 95.84 }
 PROCESS WEIGHT RATE: _____
 LEAK CHECKS: Pre Pitot <01e20" / Post Pitot <01e20"

AMBIENT TEMPERATURE: 77 F
 BAROMETRIC PRESSURE: 29.26
 ASSUMED MOISTURE: 1/2 %
 PROBE LENGTH, in.: 3 FT
 NOZZLE DIAMETER, in.: 1/4"
 STACK DIAMETER, in.: 24"
 PROBE HEATER SETTING: 250 R
 HEATER BOX SETTING: 250

PLANT: GBHSD
 DATE: 5/27/2020
 LOCATION: GREEN BAY, WI
 OPERATOR: MIM/CSM
 STACK NO.: JOB STACK
 RUN NO.: 3
 SAMPLE BOX NO.: 3
 METER BOX NO.: 3



CROSS SECTION

TRAVERSE POINT NUMBER	SAMPLING TIME (H), min.	STATIC PRESSURE (in. H ₂ O)	STACK TEMPERATURE (T _s), °F	VELOCITY HEAD (V _p) (1/16")	PRESSURE DIFFERENTIAL ACROSS ORIFICE METER (in. H ₂ O)	GAS SAMPLE VOLUME (V _m), ft ³	GAS SAMPLE TEMPERATURE AT DRY GAS METER		SAMPLE BOX TEMPERATURE °F	TEMPERATURE OF GAS LEAVING CONDENSER OR LAST IMPINGER °F	PUMP VACUUM in. Hg gauge	OPM FILTER TEMP VELOCITY fps
							INLET (T _{m,in}), °F	OUTLET (T _{m,out}), °F				
A1	11:20		123	.83	1.74	4735.00	130	235		450	2	78
2	75	-.55	123	.77	1.62	39.6	129					78
3	30		122	.72	1.51	44.0	130	250		450	2	78
4	35		122	.86	1.81	48.3	131					79
5	40	-.58	122	.99	2.08	52.9	132	255		450	2+	81
6	45		122	.92	1.93	57.8	132					82
B1	50/50		122	.65	1.37	62.6	133	245		450	2	83
2	57	-.50	122	.74	1.55	66.7	134					81
3	12:02		122	.84	1.76	71.0	136	260		450	2	81
4	07		123	.93	1.95	75.3	137					82
5	12	-.53	122	.97	2.04	80.2	138	255		450	2 1/2	83
6	17		123	.79	1.66	85.0	139					84
	12:22					4789.64						
						(54.64)						

LABORATORY DATA SHEET
PARTICULATE & WATER COLLECTED

JOB NAME GBMSD

DATE OF TEST 5-27-2020

JOB NO. _____

TEST ENGINEER MJH

RUN NO. 3 STACK. 508

Sample Box 3 Filter 291 Wash Bottle -
Beaker No. 3

WATER COLLECTED

<u>Impinger No.</u>	<u>Final Wt. g</u>	<u>Initial Wt. g</u>	<u>Collected grams</u>
<u>1</u>	<u>114</u>	<u>100</u>	<u>14</u>
<u>2</u>	<u>110</u>	<u>100</u>	<u>10</u>
<u>3</u>	<u>3</u>	<u>0</u>	<u>3</u>
<u>SILGEL</u>	<u>700</u>	<u>692</u>	<u>8</u>
		TOTAL	<u><u>35</u></u>

PARTICULATE COLLECTED

	<u>Final Wt. g</u>	<u>Tare Wt. g</u>	<u>Collected grams</u>
Filter <u>.0002</u>	<u>.3531</u>	<u>.3523</u>	<u>.0006</u>
Washings <u>-.0001</u>	<u>103.1771</u>	<u>103.1735</u>	<u>.0037</u>
		TOTAL	<u><u>.0043</u></u>

WATER COLLECTED GRAMS

PARTICULATE COLLECTED GRAMS

NOTES:

APPENDIX C

Detailed Equations of PM Calculations

SAMPLE PARTICULATE CALCULATION SHEET

TEST NO.	Sample	
BAROMETRIC PRESSURE (Pb)	29.45	IN HG
TIP DIAMETER (d)	0.305	IN
STACK DIAMETER (D)	72	IN
STACK AREA (As=PI*D^2/576)	28.274	FT2
SAMPLING TIME PER POINT	2.5	MIN
NUMBER OF POINTS	24	
METER VOLUME (Vm)	66.53	FT3
PITOT COEFFICIENT (cp)	0.84	
METER COEFFICIENT (GAMA)	0.990	
PARTICULATE COLLECTED (Mn)	0.0500	GRAMS
WATER COLLECTED (Vf-Vi)	32	ML
STATIC PRESSURE (Ps)	-0.5	IN H2O

ORSAT RESULTS

CO2	O2	CO	N2
6.40%	13.40%	0.00%	80.20%

POINT	STACK TEMP DEG F	DELTA P IN H2O	ORIFICE DEL P IN H2O	METER TEMP DEG F	VELOCITY AFPS
1	275	0.32	2.20	35	37.52
2	280	0.37	2.55	38	40.48
3	278	0.37	2.55	40	40.42
4	278	0.40	2.80	41	42.03
5	280	0.50	3.50	43	47.05
6	281	0.70	4.90	44	55.71
7	282	0.72	5.00	44	56.54
8	280	0.72	5.00	44	56.46
9	280	0.62	4.30	45	52.40
10	277	0.57	3.90	46	50.14
11	276	0.65	4.50	47	53.50
12	275	0.60	4.20	48	51.37
13	282	0.70	4.90	50	55.75
14	283	0.82	5.70	53	60.38
15	282	0.85	6.00	56	61.43
16	283	0.75	5.20	60	57.74
17	280	0.59	4.10	62	51.11
18	280	0.60	4.20	65	51.54
19	280	0.60	4.20	67	51.54
20	278	0.65	4.50	70	53.58
21	279	0.72	5.00	72	56.43
22	280	0.72	5.00	74	56.46
23	277	0.65	4.50	75	53.54
24	275	0.30	2.10	75	36.32
AVERAGE	279 (Tsavg)		4.20 (DELH)	54 (Tm)	51.23 (vsavg)

DRY STANDARD VOLUME (Vmstd)	65.51	SCF
PERCENT WATER VAPOR %H2O)	2.25	% VOL
FLOW RATE (Q)	86905	ACFM
	59651	DSCFM
	101360	M3/HR
PARTICULATE CONCENTRATION (cs)	0.0118	GR/DSCF
PARTICULATE EMISSION RATE (ER)	6.08	LB/HR
LB PART PER 1000 LB GAS (EC)	0.0219	
ISOKINETIC PERCENT (I)	102.0	

PARTICULATE SAMPLE CALCULATION FORMULA

1. **DRY MOLECULAR WEIGHT (Md)** lb/lb-mole

$$Md = .44*\% \text{ CO}_2 + .32*\% \text{ O}_2 + .28*\% \text{ N}_2 + .28*\% \text{ CO}$$

2. **WATER VAPOR PERCENT (%H₂O)**

$$Vw \text{ std} = 0.04707*(Vf - Vi)$$

where: Vw std = standard cubic feet of water vapor

Vf = Final volume of impingers, ml

Vi = Initial volume of impingers, ml

$$\% \text{H}_2\text{O} = Vw \text{ std} * 100 / (Vm \text{ std} + Vw \text{ std})$$

where Vm std = standard cubic feet of gas sampled

3. **WET MOLECULAR WEIGHT (Ms)** lb/lb-mole

$$Ms = Md*(1 - \% \text{H}_2\text{O}/100) + 18*\% \text{H}_2\text{O}/100$$

4. **STACK PRESSURE (Ps)** in. Hg.

$$Ps = Pb + Pg/13.6$$

where: Pb = barometric pressure (uncorrected), in. Hg

Pg = stack gauge pressure, in. H₂O

13.6 = specific gravity of mercury (Hg)

5. **AVERAGE STACK VELOCITY (vs)** feet per second

$$Vs = Kp * Cp * DELP * (Tsavg / (Ps * Ms))^{0.5}$$

where: Kp = 85.49 unit conversion

Cp = 0.84, pitot tube calibration factor

DELP = average of square root of velocity head, in. H₂O

Tsavg = average stack temperature, deg R (460+F)

Ps = stack pressure

Ms = wet molecular weight

6. **STACK GAS FLOW RATE (Qs)** std. cubic feet per minute

$$Q_s = 60 \cdot (1 - \%H_2O/100) \cdot V_s \cdot A \cdot (528 \cdot P_s / T_{savg} / 29.92)$$

where: A = stack area, ft²
528 = std temperature, deg R
29.92 = std pressure, in. Hg

7. **DRY GAS VOLUME (Vmstd)** dry std. cubic feet

$$V_{m \text{ std}} = (GAMAC \cdot (P_b + DELH/13.6) / 29.92) \cdot V_m$$

where: GAMAC = dry gas meter calibration factor corrected for
meter temperature (GAMA + (T_m - 70) * .00012)

V_m = volume of dry gas metered, cubic feet

T_m = average meter temperature, degrees F

DELH = average orifice pressure drop, in. H₂O

8. **PARTICULATE CONCENTRATION (cs)** grains per dry standard
cubic foot

$$C_s = M_n \cdot 15.43 / V_{m \text{ std}}$$

where: M_n = particulate captured, grams

15.43 = grains per gram

9. **EMISSION RATE (ER)** pounds per hour

$$PMRA = M_n \cdot A \cdot 60 / (t \cdot A_n \cdot 453.6) \quad \text{AREA METHOD lb/hr}$$

$$PMRC = C_s \cdot Q_s \cdot 60 / (15.43 \cdot 453.6) \quad \text{CONC. METHOD lb/hr}$$

$$ER = (PMRA + PMRC) / 2$$

where: A_n = area of sampling nozzle, square feet

10. **EMISSION CONCENTRATION (EC)** lb/1000 lb exhaust gas

$$EC = ER \cdot 386700 \cdot (1 - \%H_2O/100) / (Q_s \cdot 60 \cdot M_s)$$

where: 386700 = cubic feet per lb mole * 1000

11. **ISOKINETIC SAMPLING PERCENTAGE (I)**

$$I = PMRA / PMRC$$